CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0065:170 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Faraday, 805 S. Maumee Street, Tecumseh, MI 49286

Contact: Steven A. Blohm (517) 423-2111

DESIGN: Model RSE-300 notification appliance extender/distributed power module/power supply

and Models EN-RSE enclosure. Unit comprises of a printed circuit board housed in the EN-RSE enclosure. The RSE-300 monitors with the polarity of its two input circuits to determine when to operate its four notification circuits. The RSE-300 also provides on trouble relay contact and an auxiliary power circuit. Refer to listee's installation/operation

manual for additional detailed product description and operational considerations.

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction. Unit shall be fully

supervised and shall have the 24-hr battery back up as required per code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as notification appliance extender for use with listee's separately listed compatible

fire alarm control units.

This unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996. Refer to manufacturer's

Installation Manual for details.

XLF: 7300-0067:218

08-09-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 8, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager